

Michigan



LOAD BANK TEST

ENGINE DIVISION
1-800-833-1789

CUSTOMER NO.	CUSTOMER NAME <i>MCAT Rental</i>		W.O. # <i>9734719</i>
GENERATOR SET LOCATION <i>NIY</i>	UNIT NO. <i>MEP42000-2</i>	CONTACT <i>James Glanz</i>	TELEPHONE NO. <i>248 349 4800</i>
ENGINE MODEL	SERIAL NO.	SERVICE METER <i>19448</i>	DATE <i>7-4-19</i>
GENERATOR MODEL <i>XQ2000</i>	SERIAL NO. <i>BPD00890</i>	KW RATING <i>2000</i>	VOLTS <i>480</i> SERVICE LEVEL <i>PMI</i>

TIME	Hz	KW	VOLTS			AMPS			OIL PRESS	COOLANT TEMP	AMBIENT TEMP
			A	B	C	A	B	C			
120 0	60.1	1874	484	485	486	2233	2226	2230	63	178	41
1230 0.5	60.1	1873	485	485	486	2234	2227	2231	63	178	41
1300 1	60.1	1874	484	485	486	2233	2226	2230	63	178	41
1330 1.5	60.1	1980	484	485	485	2360	2355	2359	62	180	40
1400 2	60.1	1980	484	485	486	2360	2353	2359	62	180	41
1430 2.5	60.1	1980	484	485	486	2360	2354	2357	62	180	41
1500 3	60.1	1978	484	485	485	2359	2353	2357	62	180	41
1530 3.5	60.1	1980	484	485	486	2360	2354	2357	62	180	41
1600 4	60.1	1978	484	485	485	2358	2352	2356	62	180	40
4.5		0									
5		0									
5.5		0									
6		0									
6.5		0									
7		0									
7.5		0									
8		0									

COMMENTS, RECOMMENDATIONS

[Signature] *4-4-19*

SERVICE TECHNICIAN DATE CUSTOMER REPRESENTATIVE DATE

1941

1942

1943

1944

1945

1946

1947

1948

1949

1950

1951
1952
1953
1954
1955
1956
1957
1958
1959
1960