




|   |                           |  |                                    |                              |
|---|---------------------------|--|------------------------------------|------------------------------|
|  | OFFICIAL LOAD TEST REPORT |  | CUSTOMER<br>Mckain 300kw generator | JOB NUMBER                   |
|   | ADDRESS<br>Katy Shop      |  | DATE<br>4 21 26                    | TECHNICIAN<br>Andrew Pereira |
|   | PM CONTRACT               |  | CUSTOMER SIGNATURE                 |                              |
|   | MODEL #<br>G300LG4        |  | REQUESTED TEST TIME<br>2 Hour      |                              |
|   | SERIAL #<br>GXF03683      |  | ACTUAL TEST TIME<br>2 Hour         |                              |
|   | KW RATING<br>300          |  |                                    |                              |

NUMBER OF CABLES REQUIRED **4**      LENGTH OF CABLES **50'**

| LINE | TIME | VOLTS |       |       | AMPS |     |     | P.F. | KW  | FREQ<br>HZ | PRESSURE |      | COOLANT<br>TEMP | AVG. AMB.<br>°F | EXH. TEMP | REMARKS |
|------|------|-------|-------|-------|------|-----|-----|------|-----|------------|----------|------|-----------------|-----------------|-----------|---------|
|      |      | 01-02 | 02-03 | 01-03 | 01   | 02  | 03  | %    |     |            | OIL      | FUEL |                 |                 |           |         |
| 1    | 344  | 479   | 480   | 480   | 109  | 109 | 109 | 30   | 100 | 60         | 90       | NG   | 170             |                 | OK        |         |
| 2    | 354  | 480   | 479   | 480   | 119  | 120 | 119 | 30   | 100 | 60         | 86       | NG   | 164             |                 | OK        |         |
| 3    | 400  | 480   | 480   | 480   | 119  | 120 | 119 | 30   | 100 | 60         | 86       | NG   | 169             |                 | OK        |         |
| 4    | 410  | 479   | 480   | 479   | 155  | 156 | 156 | 50   | 150 | 60         | 86       | NG   | 170             |                 | OK        |         |
| 5    | 420  | 480   | 479   | 480   | 155  | 156 | 156 | 50   | 150 | 60         | 83       | NG   | 170             |                 | OK        |         |
| 6    | 440  | 480   | 480   | 479   | 229  | 228 | 229 | 75   | 225 | 60         | 82       | NG   | 171             |                 | Ok        |         |
| 7    | 5:00 | 480   | 480   | 480   | 229  | 228 | 229 | 75   | 225 | 60         | 82       | NG   | 173             |                 | ok        |         |
| 8    | 520  | 480   | 480   | 480   | 305  | 305 | 306 | 95   | 292 | 60         | 81       | NG   | 173             |                 | ok        |         |
| 9    | 540  | 480   | 480   | 480   | 305  | 305 | 306 | 95   | 292 | 60         | 81       | NG   | 173             |                 | ok        | 237     |
| 10   |      |       |       |       |      |     |     |      |     |            |          |      |                 |                 |           |         |
| 11   |      |       |       |       |      |     |     |      |     |            |          |      |                 |                 |           |         |
| 12   |      |       |       |       |      |     |     |      |     |            |          |      |                 |                 |           |         |
| 13   |      |       |       |       |      |     |     |      |     |            |          |      |                 |                 |           |         |
| 14   |      |       |       |       |      |     |     |      |     |            |          |      |                 |                 |           |         |

NOTES:  
Load bank test results: Pass

TESS16



[www.mckainpower.com](http://www.mckainpower.com)  
832-271-4800  
4141 Katy Hockley Rd, Katy, TX 77493