



Preventative Maintenance  
Loadbank Test Results

<b>Customer Name</b>	McKain Power Systems Consulting, LLC				<b>Customer Unit ID</b>		
<b>Street Address</b>	24727 Mount Auburn Drive Katy, TX 77494						
<b>Date of Service</b>	10/26/22	<b>Gen Volts:</b>	480	<b>Gen. KW:</b>	1000	<b>No. of Cables</b>	
<b>Test Start Time</b>	12:30	<b>Amb. Temp:</b>	78	<b>Unit Hrs:</b>	4477	<b>No. of Lug Ends</b>	
<b>Work Order No</b>	MPS0959	<b>Connecting Point</b>		<b>Bus Bar</b>		<b>No. of Plain Ends</b>	

					Mfgr.	Model			S/N:			
Engine					Cat	3508			1F200801			
Start Time	Battery Voltage	Oil Press	Fuel Press	Coolant Temp	Voltage			Amperage			KW	Hertz
					A-B	B-C	A-C	A	B	C		
1230	26.8	71	79	171	480	479	481	1120	1139	1137	1000	60
1245	26.9	68	76	178	481	480	482	1121	1141	1139	1000	60
1300	26.8	64	72	185	481	479	482	1123	1138	1138	1000	60
1315	27.0	62	71	185	480	479	482	1121	1138	1136	1000	60
1330	27.0	62	71	185	480	480	481	1120	1139	1136	1000	60
1345	27.0	68	76	178	481	482	481	0	0	0	0	60
Notes: Full PM @ 4478 hrs		1 Hour Load Test – PASSED Tested by: Shayne Bourn										